

City of Las Vegas Code and Interpretation

AMEND: 62

DATE: 11/16/2009

CODE: 2006 IBC ☐ 2005 NEC ☒ Local Amendments ☐
2006 IRC ☐ 2006 UMC ☐ POOL CODE ☐
2006 IECC ☐ 2006 UPC ☐ MISC. ☐

CODE SECTION: 2005 NEC Amendments 700.12 (B) (7)

TOPIC: Requirements for Rooftop Emergency Generators

PURPOSE/REASON: Provide clarification of the requirements for rooftop emergency generators.

INTERPRETATION:

- The roof under the emergency generator shall be protected with a minimum 2 hour rating
- The supporting structural members shall be protected with a minimum 2 hour rating
- Rated enclosure walls are not required when open to the sky
- A rated roof over the generator is not required when open to the sky.

Approved: Chris Knight, Building Official